

S.O.No. 21000819019005 dtd. 23/04/2019

Contract

Contract No: GEMC-511687759687025

Generated Date:22-Apr-2019

Organisation Details

Type: Central PSU
 Ministry: Ministry of Coal
 Department: Materials Management
 Organisation Name: Western Coalfields Ltd
 Office Zone: Western Coalfields Limited / Nagpur

Buyer Details

Name: Alok Kumar
 Designation: Asst Manager (MM)
 Contact No.: -
 Email ID: alokkumar@coalindia.in
 GSTIN: 27AAACW1578L1ZW
 Address: 1st Floor, MM Wing, WCL Hqrs, Coal Estate, Civil Lines,
 NAGPUR, MAHARASHTRA-440001, India

Financial Approval Detail

IFD Occurrence : Yes
 Designation of Administrative Approval : GM MM
 Designation of Financial Approval : GM Finance

Seller Details

Company Name: gental enterprises
 Email ID: gentalgem@gmail.com
 Address: mb 11a mansarover complex hoshangabad road,
 BHOPAL, Madhya Pradesh-462003, -

Product Details

#	Item Description	Category Name	Model	Ordered Quantity	Unit	Price (Inclusive of all Duties and Taxes in INR)
1	Online UPS	Online UPS	Online UPS	1	-	30,950
Total Order Value (in INR)						30,950

Consignee Detail

S.No	Consignee	Item	Quantity	Expected Delivery Date
1	Neeli Purushotham Chief Manager EnT Landline-0712-2510825- npurshottam@westerncoal.gov.in 1st Floor, MM Wing, WCL Hqrs, Coal Estate, Civil Lines, NAGPUR, MAHARASHTRA-440001, India	Online UPS	1	07-May-2019

Product Specification for Online UPS

Specification	Sub-Spec	Value
GENERIC	Rating in KVA (KVA)	2.0 KVA
	Technology	IGBT-PWM with inbuilt isolation transformer
	Input Power	single phase 160V - 260V sinewave,50Hz
	Output power	Single phase 230V +/-1% sinewave 50 Hz
	Backup time (Minutes)	120
	Minimum VAH (VAH)	6400
	Warranty for UPS (Years)	5
	Movable trolley for Batteries	Without
	Warranty for battery	2
Degree of Protection	IP21	

	Cabling 5 meters for input and out put	Without
	Paralleling kit for synchronising	Without
	Installation and Commissioning	Yes
CONSTRUCTIONAL	Minimum thickness of M.S.Sheet Enclosure duly painted (mm)	1.2
	Type of Battery	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)
FUNCTIONAL	Maximum overshoot and Under shoot of output rated voltage	4
	Voltage Regulation from no load to full load (%)	< / = 3%
	20% Overload limit for minimum 10 minutes	Yes
	Overall Efficiency (%)	>/=90%
	Total Harmonic Distortion(THD) (%)	Maximum 3%
	50% Overload limit for minimum 1 minutes	Yes
PROTECTION	Protection for under voltage at battery terminal at 10.5V per 12 V battery.	Yes
	Protection of Over voltage,Short Circuit & over load at UPS output terminal	Yes
METERING AND INDICATIONS	Digital Metering in UPS for AC Input Voltage,Output AC Voltage,Current,Frequency,Battery Voltage and Current	Yes
	Indicators for mains presence,Battery charging and discharging,Output Over Load, Low Battery Voltage	Yes
REPORTS AND CERTIFICATION	Damp Heat : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)	Yes
	Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	Yes
	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes
	Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.	Yes
	Type Test Certificate No.	NTH(ER)/EL(ET)/2014/0 011B
	Type Test Certificate date	26.02.2014
	Name of Lab	National Test House (Eastern Region)
	Address of Lab	Block-CP , Sector-V , Lake city, kolkata-700091,WB
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes

Terms and Conditions

1. General terms and conditions

1.1 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) as available on the GeM portal (unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

1.2 Terms of delivery: Free Delivery at Site including loading/unloading. In respect of items requiring installation and / or commissioning and other services in the scope of supply (as indicated in respective product category specification / STC / ATC), and the cost of the same is also included in the Contract price.

1.3 Delivery period: The Delivery Period/Time shall be essence of the Contract and delivery must be completed not later than such date(s). Any modification thereto shall be mutually agreed and incorporated in the Contract as per the provisions of the GTC.

1.4 Performance Security: If the Seller fails or neglects to observe or perform any of his obligations under the contract it shall be lawful for the Buyer to forfeit either in whole or in part, the Performance Security furnished by the Seller.

1.5 Taxes and Duties: Contract Prices are all inclusive i.e. including all taxes, duties, local levies / transportation / loading-unloading charges etc. Break up of GST