

Contract



21100817721263 DT. 6-Jan-2022

Contract No: GEMC-511687714419704

Generated Date: 06-Jan-2022

Bid/RA/PR No: [GEM/2021/B/1046133](#)

Organisation Details	Buyer Details
Type: Central PSU	Designation: Deputy Manager
Ministry: Ministry of Coal	Contact No.: 0712-2511381-
Department: Materials Management	Email ID: alokkumar@westerncoal.gov.in
Organisation Name: Western Coalfields Ltd	GSTIN: 27AAACW1578L1ZW
Office Zone: Western Coalfields Limited / Nagpur	Address: WCL Hqrs, Coal Estate, Civil Lines, NAGPUR, MAHARASHTRA-440001, India

Financial Approval Detail	Paying Authority Details
IFD Concurrence: No	Payment Mode: Offline
Designation of Administrative Approval: GM MM Purchase	Designation: Dy Manager Fin
Designation of Financial Approval: GM Finance	Email ID: sprathi@westerncoal.gov.in
	GSTIN: 27AAACW1578L1ZW
	Address: WCL Hqrs, Coal Estate, Civil Lines, NAGPUR CITY, MAHARASHTRA-440001, India

Seller Details	
GeM Seller ID:	E343180000103305
Company Name:	SSS Associates
Contact No.:	09373107962
Email ID:	sssassociates.nagpur@gmail.com
Address:	190 M-1,SHRIRAM COMPLEX,LIT Road,,RAM NAGAR, Nagpur, MAHARASHTRA-440010, -
MSME verified:	Yes
MSME Registration number:	MH20E0022621
GSTIN:	27ABSF52328A1Z7

*GST / Tax invoice to be raised in the name of - Consignee

Product Details								
#	Item Description	Category Name & Quadrant	Model	HSN Code	Ordered Quantity	Unit	Lead Time(Days)	Price (Inclusive of all Duties and Taxes in INR)
1	Product Name : ceasefire watermist and caf fire extinguisher high pressure back pack type of Corrosion Free Aluminum alloy vessel of 10 litre capacity . Brand : ceasefire Brand Type : Registered Brand Catalogue Status : Catalogue not verified by OEM Selling As : OEM verified Reseller	watermist and caf fire extinguisher high pressure back pack type (Q2)	Ceasefire CF-000981 (SF)	HSN not specified by seller	9	pieces	-	1,699,200
Total Order Value (in INR)								1,699,200

Consignee Detail						
S.No	Consignee	Item	Lot No.	Quantity	Delivery Start After	Delivery To Be Completed By
1	Designation: - Email ID: ujawal.rane@nic.in Contact: 07173-254042- GSTIN: 27AAACW1578L1ZW Address: Regional Stores, WCL Ballarpur Area PO Sasti Distt Chandrapur (M.S) Pin 442 706, Chandrapur, MAHARASHTRA-442706, India	ceasefire watermist and caf fire extinguisher high pressure back pack type of Corrosion Free Aluminum alloy vessel of 10 litre capacity .	-	4	06-Jan-2022	07-Mar-2022
2	Designation: - Email ID: ulli.srikanthganesh@nic.in Contact: 07172-271036-265351 GSTIN: 27AAACW1578L1ZW Address: Regional Stores, WCL, Durgapur Opencast, P.O. DURGAPUR Distt Chandrapur, (M.S)Pin 442 403,	ceasefire watermist and caf fire extinguisher high pressure back pack type of Corrosion Free Aluminum alloy vessel of 10 litre capacity .	-	5	06-Jan-2022	07-Mar-2022

Product Specification for ceasefire watermist and caf fire extinguisher high pressure back pack type of Corrosion Free Aluminum alloy vessel of 10 litre capacity .

Specification	Sub-Spec	Value
Generic	"Conformity to EN 3-7:2004+A1:2007-08 standards "	The complete system shall be tested for compliance from an internationally/nationally accredited laboratory for compliance to all 30 clauses (3.2, 3.15, 4.2, 4.3, 4.4, 4.5, 6.1, 6.2, 6.3, 7.1.1, 7.1.2, 7.2, 7.3, 7.4, 8.1, 8.2, 9.2, 10.1, 10.2, 10.3, 10.4, 10.5, 10.6.1 & 10.6.2, 14.1, 14.2, 15.2, 15.3, 16.1, 16.2) of EN 3 - 7:2004 + A1: 2007-08 (E) Standard mandatorily applicable for the complete system
	Mounting type	Backpack
	Configuration (Shall be mounted on a sturdy frame suitably cushioned for comfort, provided with shoulder pads for carrying as a backpack and a handle to be carried by hand. All materials used shall be of fire retardant type. Backpack shall be supplied with two air cylinders.)	Yes
	Model Number as per Accredited Laboratory Test Report to Be declared	CF-000981
	Main Components: Pressure vessel to hold the media with safety valve, compressed air cylinder coupled with a reducer, hose pipes for discharge of water mist media, extinguishing gun.	Yes
Constructional	Air Cylinder Material	Steel
	Type of Foam	Special AFFF Compound conforming to manufacturer own specifications for higher fire rating A55, B233, Spreading coefficient for special AFFF Compound shall be +5 minimum, concentration shall be 6%.
	If special foam mention the composition for special ,otherwise put NA	Water 74%, Butyl Di Glycol 10%, Metal Salt 2%, Mixture of Hydrocarbon and Fluorinated Surfactants 12%
	Commercial Brand Name of the Special foam (fire extinguishing medium) as per accredited laboratory test report wherein higher fire ratings i.e A55,B233, E1000 V (Die Electric Suitability) achieved, to be declared.Write NA if not applicable.	CF SP Agent (SM-RM2745A)
	Characteristics of extinguishing medium of Special AFFF Compound (manufacturer own specifications) with infrared spectrogram to be furnished.NA if not applicable	pH 7.92, Specific gravity 1.012, Viscosity 1.13 cst, Refractive index at 20deg C 1.343
	Pressure Vessel Material & Capacity (Nominal Charge)	Corrosion Free Aluminum alloy vessel of 10 litre capacity .
	Minimum wall thickness of pressure vessel (mm)	5
	Extinguishing gun material	Stainless Steel
	if others Mentions the material for Extinguishing gun,otherwise put NA	NA
	Extinguishing gun weight (750 grams approx)	814
	Length of EN marked Hose 1.3 meter for backpack system	Yes
	Weight of fully charged Backpack system between 25kg to 27kg having Corrosion Free Aluminum Alloy vessel and below 20 kg having Ultralite Carbon Composite with PET Liner Vessel for	25.59
performance	Air Cylinder Capacity (Ltrs)	2
	Air Cylinder pressure (Bar)	200
	High Pressure Type (Dynamic Operating pressure to be tested in the accredited laboratory test report which will be considered as high pressure for as per clause No. 3.15 of EN 3 - 7:2004 + A1: 2007-08 (E) Standard.) ≥ 30 for Aluminium vessel , ≥ 35 for Ultralight Carbon composite with PET Liner vessel (Bar)	31
	Lancing Distance of Gun : More than 12 meter (meter)	13.2
	The air hoses shall be suitable for minus 40 deg C to 100 Deg C temperature and EN mark on hose	Yes
	Minimum operating time in full throttle for aluminium alloy vessel	41.33
	Minimum operating time in full throttle for Ultralight Carbon composite with PET Liner vessel	NA
	System shall be designed for maximum operating temperature TS max and minimum operating temperature TS min of 60 deg C or more and 5 Deg C or less respectively and certified by the	Yes

	manufacturer accordingly as per Clause 7.4 of EN 3-7:2004+A1:2007-08 standards as per the accredited test report for backpack system.	
	Fire Rating	55 A, 233B, 1000V with Special AFFF Compound as per manufacturer own specn
Certification	PED approval as per Directive 97/23/EC	Yes
	Pressure Vessel shall include a pressure gauge fitted on the vessel (CE Marked from notified body).	Yes
	No objection certificate (NOC) for Pressure Vessel from Petroleum and Explosives Safety Organization (PESO) Nagpur	Yes
	Pressure Vessel should have CE Marking from Notified body	Yes
	The air cylinders shall have PESO, Nagpur approval	yes
	Specific consent of the OEM for the value additions made along with a confirmation that fire ratings of the equipment would not be affected by these value additions.	Yes
	Test Report No	952,160801,00122A
	Test Report Date	4.10.18,2.5.18
	Name of ILAC/NABL/Central Govt. Accredited Laboratory where Test Conducted	AFTRL, NTH
	NOC Letter No. Date of PESO Nagpur for Pressure Vessel	G.3(4)40/Mics/2017, dated - 12.04.2017

Buyer Defined Additional Specification for ceasefire watermist and caf fire extinguisher high pressure back pack type of Corrosion Free Aluminum alloy vessel of 10 litre capacity .

Specification	Value
Following certificates have to be submitted along with the bid: PED approval as per Directive 97/23/EC Pressure Vessel shall include a pressure gauge fitted on the vessel (CE Marked from notified body).	NOC for Pressure Vessel from PESO Nagpur Pressure Vessel should have CE Marking from Notified body The air cylinders shall have PESO, Nagpur approval Specific consent of the OEM for the value additions made along with a confirmation that fire ratings of the equipment would not be affected by these value additions. Test Report No& Date Name of ILAC/NABL/Central Govt. Accredited Laboratory where Test Conducted NOC Letter No. Date of PESO Nagpur for Pressure Vessel

Terms and Conditions

1. General Terms and Conditions-

1.1 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) as available on the GeM portal (unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

1.2 Terms of delivery: Free Delivery at Site including loading/unloading. In respect of items requiring installation and / or commissioning and other services in the scope of supply (as indicated in respective product category specification / STC / ATC), and the cost of the same is also included in the Contract price.

1.2.1 Contracted goods should be delivered at the consignee or designated delivery location as per the working time of the buying organisation. Seller may get the same confirmed from consignee before scheduling delivery.

1.2.2 A copy of the contract should be available with the messenger / dispatching agency that delivers the Goods at consignee / delivery location (preferably pasted / attached outside the consignment / package) for easy reference and ease in delivery acceptance.

1.3 Delivery period: The Delivery Period/Time shall be essence of the Contract and delivery must be completed not later than such date(s). Any modification thereto shall be mutually agreed and incorporated in the Contract as per the provisions of the GTC.

1.4 Performance Security: If the Seller fails or neglects to observe or perform any of his obligations under the contract it shall be lawful for the Buyer to forfeit either in whole or in part, the Performance Security furnished by the Seller.

1.5 Taxes and Duties: Contract Prices are all inclusive i.e. including all taxes, duties, local levies / transportation / loading-unloading charges etc. Break up of GST shall be indicated by the Seller while raising invoice / bill on GeM. While submitting the bill / invoice Seller shall undertake that the Goods and Services Tax (GST) charged on this bill is not more than what is payable under the provision on the relevant Act or the Rules made there under and that the Goods on which GST has been charged have not been exempted under the GST Act or the Rules made there under and the charges on account of GST on these goods are correct under the provision of that Act or the rules made there under.

1.6 Octroi Duty and / or other local taxes:Contract Prices are all inclusive hence no reimbursement over and above the contract price(s) shall be allowed to seller towards payment of local taxes (such as levy of town duty, Octroi Duty, Terminal Tax and other levies of local bodies etc).

1.7 Limitation of Liability: The provisions of limitation of liability between Buyer and Seller as given in the GTC shall be applicable here.

1.8 Resolution of disputes: The provisions of DISPUTE RESOLUTION BETWEEN BUYER AND SELLER as given in the GTC shall be applicable here.

1.9 Liquidated Damages: If the Seller fails to deliver any or all of the Goods/Services within the original/re-fixed delivery period(s) specified in the contract, the Buyer will be entitled to deduct/recover the Liquidated Damages for the delay, unless covered under Force Majeure conditions aforesaid, @ 0.5% per week or part of the week of delayed period as pre-estimated damages not exceeding 10% of the contract value without any controversy/dispute of any sort whatsoever. In case, Service Level Agreement (SLA) is applicable the same shall be applicable for the Contract.

1.10 Financial Certificate:

1.10.1 The expenditure involved for this purpose has received the Sanction of the competent financial authority.

1.10.2 The funds are available under the proper head in the sanction budget allotment for the concern financial year.

1.10.3 I have been fully authorized by the department to sign the supply order or incur the liability of the Goods being ordered.

1.11 The bidder should submit a self declaration to the effect in bidder's official letter head that their agency have not been black listed by any Agency whatsoever till date.

2. Buyer Added Bid Specific Terms and Conditions-

2.1 Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

2.2 To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid): PED approval as per Directive 97/23/EC PressureVessel shall include pressuregauge on vessel(Pressure Vessel should have CE Marking from Notified body). NOC for Pressure Vessel from PESO Nagpur/ air cylinders have PESO, Nagpur approval Specific consent of the OEM for the value additions made along with a confirmation that fire ratings of the equipment would not be affected by these value additions. Test Report No& Date Name of ILAC/NABL/Central Govt. Accredited Laboratory where Test Conducted.

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.